

**OFFICE OF THE SUPERINTENDENT OF SCHOOLS**  
**Ridgefield Park Public Schools**  
**712 Lincoln Avenue**  
**Ridgefield Park, New Jersey 07660**

*Eric W. Koenig*  
*Superintendent of Schools*

*Telephone: (201) 807-2638*  
*(201) 807-2640*  
*Fax: (201) 641-2203*

August, 2016

Dear Parents/Guardians,

Due to the concerns raised about lead in drinking water that was found in several school districts around the State, the Ridgefield Park School District made a decision to test the lead levels in the drinking fountains and other water sources in all of the district school buildings this past Spring.

The district contracted with ALS Environmental to conduct the tests. Samples were collected on May 24<sup>th</sup> and 25<sup>th</sup> according to specific sampling guidelines. Below is a summary of the results recorded in analytic reports received in June. According to federal regulations, an acceptable lead level for potable water sources is **.015 PPM**.

**Lead Testing Summary**

School	Total Sites Tested	# Sites No Lead Detected	# Sites with levels less than .015	# Sites Exceeding .015	Potable Sites Exceeding .015 (water fountains or food prep stations)
Grant	16	3	10	3	0
Lincoln	29	18	9	2	0
RPJSHS	39	4	16	19	3
Roosevelt	13	6	3	4	0
TJELC	14	8	6	0	0

While I am happy to report that very few potable sites tested above allowable levels, it is imperative that every precaution is taken to ensure the safety of everyone in our school community. As such, the potable sites exceeding the lowest allowable limit (listed below) were all shut down pending further action by the district.

JSHS Water Fountain by elevator (1<sup>st</sup> Floor)  
JSHS Water Fountain by AV Office  
JSHS Water Fountain by Rm 117

The full environmental reports can be found on the district website, in the Business Office or in the Main Office of each respective school.

Should you have any questions or concerns, feel free to contact your building principal.

Best regards,

Eric W. Koenig  
Superintendent of Schools

June 8, 2016

Mr. Mike Alberque  
Ridgefield Park School District  
712 Lincoln Ave.  
Ridgefield Park, NJ 07660

## Certificate of Analysis

Project Name:	<b>2016PC- Lead Testing in Drinking</b>	Workorder:	<b>2147247</b>
Purchase Order:		Workorder ID:	<b>Grant School-Lead in DW</b>

Dear Mr. Alberque:

Enclosed are the analytical results for samples received by the laboratory on Friday, May 27, 2016.

The ALS Environmental laboratory in Middletown, Pennsylvania is a National Environmental Laboratory Accreditation Program (NELAP) accredited laboratory and as such, certifies that all applicable test results meet the requirements of NELAP.

If you have any questions regarding this certificate of analysis, please contact Mrs. Kelli L Wolfgang (Project Coordinator) at (717) 944-5541.

Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state requirements. The test results meet requirements of the current NELAP standards or state requirements, where applicable. For a specific list of accredited analytes, refer to the certifications section of the ALS website at [www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads](http://www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads).

This laboratory report may not be reproduced, except in full, without the written approval of ALS Environmental.

ALS Spring City: 10 Riverside Drive, Spring City, PA 19475 610-948-4903



Mrs. Kelli L Wolfgang  
Project Coordinator

*This page is included as part of the Analytical Report and must be retained as a permanent record thereof.*

### ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

## SAMPLE SUMMARY

Workorder: 2147247 Grant School-Lead in DW

Lab ID	Sample ID	Matrix	Date Collected	Date Received	Collected By
2147247001	GS-BM-AR	Drinking Water	5/24/2016 06:35	5/27/2016 19:00	Collected by Client
2147247002	GS-BM-WF	Drinking Water	5/24/2016 06:35	5/27/2016 19:00	Collected by Client
2147247003	GS-1F-FBR	Drinking Water	5/24/2016 06:40	5/27/2016 19:00	Collected by Client
2147247004	GS-1F-HWF	Drinking Water	5/24/2016 06:40	5/27/2016 19:00	Collected by Client
2147247005	GS-1F-FR	Drinking Water	5/24/2016 06:40	5/27/2016 19:00	Collected by Client
2147247006	GS-1F	Drinking Water	5/24/2016 06:40	5/27/2016 19:00	Collected by Client
2147247007	GS-1F-GBR	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147247008	GS-1F-BBR	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147247009	GS-1F-NO	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147247010	GS-2F-Room C-23	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147247011	GS-2F-Room C-24	Drinking Water	5/24/2016 06:50	5/27/2016 19:00	Collected by Client
2147247012	GS-2F-BBR	Drinking Water	5/24/2016 06:50	5/27/2016 19:00	Collected by Client
2147247013	GS-2F-GBR	Drinking Water	5/24/2016 06:50	5/27/2016 19:00	Collected by Client
2147247014	GS-2F-HWF	Drinking Water	5/24/2016 06:50	5/27/2016 19:00	Collected by Client
2147247015	GS-2F-Room C-25	Drinking Water	5/24/2016 06:50	5/27/2016 19:00	Collected by Client
2147247016	GS-3F	Drinking Water	5/24/2016 06:50	5/27/2016 19:00	Collected by Client

## ALS Environmental Laboratory Locations Across North America

**Canada:** Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife **United States:** Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York **Mexico:** Monterrey

## SAMPLE SUMMARY

Workorder: 2147247 Grant School-Lead in DW

### Notes

- Samples collected by ALS personnel are done so in accordance with the procedures set forth in the ALS Field Sampling Plan (20 - Field Services Sampling Plan).
- All Waste Water analyses comply with methodology requirements of 40 CFR Part 136.
- All Drinking Water analyses comply with methodology requirements of 40 CFR Part 141.
- Unless otherwise noted, all quantitative results for soils are reported on a dry weight basis.
- The Chain of Custody document is included as part of this report.
- All Library Search analytes should be regarded as tentative identifications based on the presumptive evidence of the mass spectra. Concentrations reported are estimated values.
- Parameters identified as "analyze immediately" require analysis within 15 minutes of collection. Any "analyze immediately" parameters not listed under the header "Field Parameters" are performed in the laboratory and are therefore analyzed out of hold time.
- Method references listed on this report beginning with the prefix "S" followed by a method number (such as S2310B-97) refer to methods from "Standard Methods for the Examination of Water and Wastewater".
- For microbiological analyses, the "Prepared" value is the date/time into the incubator and the "Analyzed" value is the date/time out the incubator.

### Standard Acronyms/Flags

J	Indicates an estimated value between the Method Detection Limit (MDL) and the Practical Quantitation Limit (PQL) for the analyte
U	Indicates that the analyte was Not Detected (ND)
N	Indicates presumptive evidence of the presence of a compound
MDL	Method Detection Limit
PQL	Practical Quantitation Limit
RDL	Reporting Detection Limit
ND	Not Detected - indicates that the analyte was Not Detected at the RDL
Cntr	Analysis was performed using this container
RegLmt	Regulatory Limit
LCS	Laboratory Control Sample
MS	Matrix Spike
MSD	Matrix Spike Duplicate
DUP	Sample Duplicate
%Rec	Percent Recovery
RPD	Relative Percent Difference
LOD	DoD Limit of Detection
LOQ	DoD Limit of Quantitation
DL	DoD Detection Limit
I	Indicates reported value is greater than or equal to the Method Detection Limit (MDL) but less than the Report Detection Limit (RDL)
(S)	Surrogate Compound
NC	Not Calculated
*	Result outside of QC limits

## ALS Environmental Laboratory Locations Across North America

**Canada:** Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife **United States:** Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York **Mexico:** Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247001**

Date Collected: 5/24/2016 06:35

Matrix: Drinking Water

Sample ID: **GS-BM-AR**

Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
------------	---------	------	-------	-----	--------	----------	----	----------	----	------

**METALS**

Lead, Total	0.039		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:25	ZMC	A1
-------------	-------	--	------	--------	-----------	--------------	-----	--------------	-----	----

Mrs. Kelli L Wolfgang

Project Coordinator

**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247002**  
Sample ID: **GS-BM-WF**Date Collected: 5/24/2016 06:35 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:38	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247003**  
Sample ID: **GS-1F-FBR**Date Collected: 5/24/2016 06:40 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.0051		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:40	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247004**  
Sample ID: **GS-1F-HWF**Date Collected: 5/24/2016 06:40 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.0031		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:43	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey



**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247005**  
Sample ID: **GS-1F-FR**Date Collected: 5/24/2016 06:40 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.0083		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:46	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247006**  
Sample ID: **GS-1F**Date Collected: 5/24/2016 06:40 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.0041		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:48	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

## ANALYTICAL RESULTS

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247007**  
Sample ID: **GS-1F-GBR**

Date Collected: 5/24/2016 06:45 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
------------	---------	------	-------	-----	--------	----------	----	----------	----	------

### METALS

Lead, Total	0.0067		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:51	ZMC	A1
-------------	--------	--	------	--------	-----------	--------------	-----	--------------	-----	----



Mrs. Kelli L Wolfgang  
Project Coordinator

### ALS Environmental Laboratory Locations Across North America

**Canada:** Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife **United States:** Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York **Mexico:** Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247008**  
Sample ID: **GS-1F-BBR**Date Collected: 5/24/2016 06:45 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.0037		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:54	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247009**  
Sample ID: **GS-1F-NO**Date Collected: 5/24/2016 06:45 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.0050		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:56	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247010**  
Sample ID: **GS-2F-Room C-23**Date Collected: 5/24/2016 06:45 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.012		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 05:59	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247011**  
Sample ID: **GS-2F-Room C-24**Date Collected: 5/24/2016 06:50 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.049		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 06:02	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247012**  
Sample ID: **GS-2F-BBR**Date Collected: 5/24/2016 06:50 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
------------	---------	------	-------	-----	--------	----------	----	----------	----	------

**METALS**

Lead, Total	0.014		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 06:10	ZMC	A1
-------------	-------	--	------	--------	-----------	--------------	-----	--------------	-----	----

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey



**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247013**  
Sample ID: **GS-2F-GBR**Date Collected: 5/24/2016 06:50 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	0.020		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 06:12	ZMC	A1

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey



**ALS Environmental**



34 Dogwood Lane ■ Middletown, PA 17057 ■ Phone: 717-944-5541 ■ Fax: 717-944-1430 ■ www.alsglobal.com

NELAP Certifications: NJ PA010 , NY 11759 , PA 22-293 DoD ELAP: A2LA 0818.01  
State Certifications: DE ID 11 , MA PA0102 , MD 128 , VA 460157 , WV 343

## ANALYTICAL RESULTS

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247014**  
Sample ID: **GS-2F-HWF**

Date Collected: 5/24/2016 06:50 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
<b>METALS</b>										
Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 06:15	ZMC	A1

*Kelli Wolfgang*

Mrs. Kelli L Wolfgang  
Project Coordinator

## ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247015**  
Sample ID: **GS-2F-Room C-25**Date Collected: 5/24/2016 06:50 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
------------	---------	------	-------	-----	--------	----------	----	----------	----	------

**METALS**

Lead, Total	0.036		mg/L	0.0020	EPA 200.8	6/8/16 00:50	ZMC	6/8/16 06:18	ZMC	A1
-------------	-------	--	------	--------	-----------	--------------	-----	--------------	-----	----

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

**ANALYTICAL RESULTS**

Workorder: 2147247 Grant School-Lead in DW

Lab ID: **2147247016**  
Sample ID: **GS-3F**Date Collected: 5/24/2016 06:50 Matrix: Drinking Water  
Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
------------	---------	------	-------	-----	--------	----------	----	----------	----	------

**METALS**

Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/8/16 00:51	ZMC	6/8/16 06:20	ZMC	A1
-------------	----	--	------	--------	-----------	--------------	-----	--------------	-----	----

Mrs. Kelli L Wolfgang  
Project Coordinator**ALS Environmental Laboratory Locations Across North America**Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay  
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey




34 Dogwood Lane  
Middletown, PA 17057  
P. 717-944-5341  
F. 717-944-1430

Environmental

CHAIN OF CUSTODY/  
REQUEST FOR ANALYSIS  
ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT /  
SAMPLER. INSTRUCTIONS ON THE BACK.

COC #:

ALS Quot



Client Name: Ridgefield Park School District		Container Type	P	ANALYSES/METHOD REQUESTED	
Address: 712 Lincoln Avenue		Container Size	250 mL		
Ridgefield Park, NJ 07660		Preservative	HNO3		
Contact: Mike Alberque					
Phone#: 201-440-0808					
Project Name#: Grant School - Lead in DW					
Bill To:					
<input checked="" type="checkbox"/> Normal-Standard TAT is 10-12 business days.					
<input type="checkbox"/> Rush-Subject to ALS approval and surcharges.					
Date Required: _____ Approved By: _____					
Email? <input checked="" type="checkbox"/> Y. malberque@rpps.net					
Fax? <input type="checkbox"/> Y No.:					
Sample Description/Location (as it will appear on the lab report)	Sample Date	Time	Matrix	G or C	Total Lead by EPA 200.8
1 GS-BM-AR	5/24	635	DW	G	1
2 GS-BM-WF	1	635	DW	G	1
3 GS-1F-FBR	1	640	DW	G	1
4 GS-1F-HWF		640	DW	G	1
5 GS-1F-FR		640	DW	G	1
6 GS-1F		640	DW	G	1
7 GS-1F-GBR		645	DW	G	1
8 GS-1F-BBR		645	DW	G	1
9 GS-1F-NO		645	DW	G	1
10 GS-2F-Room C-23		645	DW	G	1
Project Comments:		LOGGED BY (signature): <i>Charles Handt</i> Date: 5/25 Time: 10:10			
Relinquished By / Company Name		REVIEWED BY (signature): <i>Phyllis</i> Date: 5/25 Time: 10:10			
1 <i>Sample</i>		Date	Time	Received By / Company Name	
3 <i>Sample</i>	5/27 1345			<i>Handt</i>	
5 <i>Sample</i>	5/27 1400			<i>Handt</i>	
7					
9					


Cooler Temp: 22°C Therm ID: 300		No. of Coolers: Y N Initial <i>Handt</i>
Custody Seals Present?		
(if present) Seals Intact?		
Received on Ice?		
COC Labels Complete/Accurate?		
Cont. In Good Cond.?		
Correct Containers?		
Correct Sample Volumes?		
Correct Preservation?		
Headspace/Volatiles?		
Courier/Tracking #:		
Sample/COC Comments:		

*Lead BM- Ant Regen*  
*Lead GS-BM*

ALS Field Services: <input checked="" type="checkbox"/> Pickup <input type="checkbox"/> Labor <input type="checkbox"/> Composite Sampling <input type="checkbox"/> Rental Equipment <input type="checkbox"/> Other:	
Standard <input type="checkbox"/>	Deliverables <input type="checkbox"/>
CLP-like <input type="checkbox"/>	USACE <input type="checkbox"/>
USACE <input type="checkbox"/>	Navy <input type="checkbox"/>
Reportable to PADEP? Yes <input type="checkbox"/>	Sample Disposal Lab <input type="checkbox"/>
PWSID #	Special <input type="checkbox"/>
EDDS: Format Type	

State Samples Collected In: NY ☐ NJ ☐ PA ☐ NC ☐



CHAIN OF CUSTODY/  
REQUEST FOR ANALYSIS

**ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT /  
SAMPLER. INSTRUCTIONS ON THE BACK**

COC #:	247	of
ALS Quote #:		

Client Name: Ridgefield Park School District		Address: 712 Lincoln Avenue		Ridgefield Park, NJ 07660	
Contact: Mike Alberque		Phone#: 201-440-0808		Project Name/ID: Grant School - Lead in DW	
Bill To:		TAT		Date Required:	
Sample Description/Location		Sample Date		Time	
1 GS-2F-Room C-24	5/24	6:00			
2 GS-2F-BBR	5/24	6:00			
3 GS-2F-GBR	5/24	6:00			
4 GS-2F-HWF	5/24	6:00			
5 GS-2F-Room C-25					
6 GS-2F					
7					
8					
9					
10					

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27		13:45	
3		Jen S		5/27		17:00	
5		Jen S		5/27		19:00	
7		Jen S		5/27		19:00	
9		Jen S		5/27		19:00	

Project Comments:		Relinquished By / Company Name		Date		Time	
1		Jen S		5/27			

ALS ENVIRONMENTAL SHIPPING ADDRESS: 34 DOGWOOD LANE, MIDDLETOWN, PA 17057